

Distributed PSO Algorithm for Data Model Partitioning in Power Distribution Systems

A. Erdeljan, D. Capko*, S. Vukmirovic, D. Bojanic and V. Congradac

Faculty of Technical Sciences
University of Novi Sad
Serbia
*dcapko@uns.ac.rs

ABSTRACT

This paper presents a method for data model partitioning of power distribution network. Modern Distribution Management Systems which utilize multiprocessor systems for efficient processing of large data model are considered. The data model partitioning is carried out for parallelization of analytical power calculations. The proposed algorithms (Particle Swarm Optimization (PSO) and distributed PSO algorithms) are applied on data model describing large power distribution network. The experimental results of PSO and distributed PSO algorithms are presented. Distributed PSO algorithm achieves significantly better results than the basic PSO algorithm.

Keywords: Particle swarm optimization, Partitioning algorithms, Power distribution networks, Data models.

1. Introduction

The trend to integrate a power distribution system with other systems within the Smart Grid (SG), effects on expanding the functionality of the Distribution Management System (DMS) [1, 2]. It also expands the data model of the distribution network. This extension applies not only to increase the amount of data (which types are already present in the model), but also to increase the granularity (the introduction of new types of data) [3, 4] - eg. the introduction of "smart" meters in the AMI subsystems, management of energy use in the home systems (HAN subsystem), and others. In this way a large amount of data from the field are presented. It increases the operational efficiency of DMS systems and provides more data to other subsystems within the SG system. Integration with GIS systems expands the data model with geographic data, and the introduction of new (renewable) energy sources in distribution networks [1] can greatly change the topological structure of the network and increase the complexity of most analytical power calculations [5]. In addition, specified analytic functions (eg Topology Analyser (TA), Load Flow (LF), State Estimation (SE), Fault Calculation (FC), Performance Indices (PI), Volt/Var Control (VVC), etc.) will be used more frequent within the SG

system and should be extended to the low-voltage part of the network to the individual consumer.

Based on the above, it can be concluded that in the modern SG system of amounts of data, which are under the jurisdiction of the DMS system, increase significantly. Furthermore, the analytical power functions are performed more complexly and more frequently. Integration and communication with other subsystems within the SG system additionally affects the DMS system, so it is necessary to find a solution to decrease the pressure on the system in conditions of frequent execution of analytical functions. The most acceptable solution is to divide the data model into parts, over which the calculations are carried out independently and to perform calculations in parallel.

The problem of data model partitioning can be reduced to the problem of weighted graph partitioning. In addition, graph vertices are subsets of data corresponding to the maximum independent calculation regions. For most analytical power functions (e.g., LF, SE, VVC, et al.) calculation regions are roots (groups of electrical elements powered from the same

source). The quantitative measures of the connection between the roots can be the number of the open switch equipment between the roots (tie switches). Therefore, graph edges represent open switches between elements from different roots. The weight of the vertex is determined by the calculation complexity of the corresponding root and the weight of edge are defined as the number of open switches between the corresponding roots [6].

The problem of graph partitioning is NP complete problem [7]. For the solution of this problem evolutionary algorithms [8] are used (such as genetic algorithm [9], ant colony optimization, Particle Swarm Optimization, and others). Some of the algorithms achieve very good results in small graphs (up to 100 vertices), while some methods [10] are very good on big graphs (several million vertices). In this paper, classical PSO and Distributed PSO algorithm are studied.

The paper is organized in the following way: section 2 describes the data model of a power distribution network. Section 3 describes the procedure for the data model partitioning and definitions of the optimization problem. The PSO and distributed PSO algorithms for the data model partitioning are presented in Section 4. Section 5 describes experimental setup, presents and discusses the results. Section 6 is a conclusion.

2. Data model partitioning

2.1 Data model in power distribution network

Grid computing is a new approach in scientific applications. Recent advances in grid infrastructure and middleware development have enabled various types of applications in science and engineering to be deployed on the Grid. The applications include those for climate modeling, computational chemistry, bioinformatics and computational genomics, remote control of instruments, and distributed databases [4]. Computational grids have recently attracted considerable attention as cost-effective platforms for parallel processing [2].

The tendency to integrate with other systems in the SG system. Leads to exchange data according to rules that are specified by standards. On other

hand, the data model should follow the rules in order for the system to function efficiently. The most used and generally accepted standard for describing data model of power systems is the CIM standard. It is introduced by IEC (International Electrotechnical Commission) and defined as part of IEC 61970-301 standard [11]. Basic electrical objects (primarily used for transmittable networks) are defined in this standard. Standard IEC 61968-11 [12] was later introduced and contains objects specific for distribution systems. Furthermore, the standardized interfaces for data exchange are defined – such as Generic Data Access standard (IEC 61970-403 [13]) which is based on Data Access Facility specification, developed by OMG group [14, 15]. The partitioning of the large data model that describes distribution networks, based on CIM standards [16], is discussed in this paper.

The CIM model is an abstract object model that represents the most significant entities of the power networks, transmission and distribution, and their relations. The distribution network data model has mostly a weakly meshed and radial structure. As such, it is suitable for graph presentation and easily transformed into a graph (the called initial graph), the edges of which represents conducting equipment, and the vertices the relation among them.

2.2 Procedure of model partitioning

The process of partitioning large datasets consists of the following phases [17]:

- 1) formation of the initial graph,
- 2) topological analysis and creation of the graph for calculations (coarsened graph), and
- 3) partitioning of the coarsened graph.

1. Formation of the initial graph

The initial graph is derived from the conduction elements and other equipment involved in the calculations. The edges of the initial graph are: (i) double ended equipment, (ii) single ended equipment with one fictive vertex. The transformers with two windings are presented with two edges (primary + derived), and transformers

with three windings are presented with three edges (primary + two derived). The vertices are connectivity nodes.

2. Topological analysis and creating of the graph for calculations

Topological analysis is one of the DMS functions. It depends on the status of conducting equipment; for instance, the state of the switches (open/closed). The analysis determines the basic group of elements (calculation regions) necessary for the calculations. The result of the analysis is a calculation domain D that could be represented by undirected weighted graph $G = (V, E)$ with vertices (V) and edges (E).

The weight of vertex v_i ($w(v_i)$) depends on the complexity of the calculation for the appropriate region R_i . If Load Flow (LF) function is considered, it can be inferred that the complexity of the LF calculation is linearly proportional to the total number of elements in the region. Therefore the weight of vertex v_i is equal to the number of elements

in the region R_i . The weight of edge $e_{ij} = (v_i, v_j)$ ($w(e_{ij})$) is equal to the number of the potential connections between elements of two regions (for example there are 3 open switches between regions $R1$ and $R2$, therefore $w(e_{1,2})=3$). Thus, for example, for LF calculations, the initial graph model from Figure 2 would be transformed into the coarsened graph shown in Figure 3.

The problem of graph partitioning is based on partitioning of the undirected graph with vertices and edges that have a certain weight. The result of p -way partitioning is a set of p partitions $\Pi = \{\pi_1, \pi_2, \dots, \pi_p\}$, where partition π_i contains an optimal set of regions (vertices).

2.3 Optimization criterion

In order to define optimization criterion, for a partition π_k it is needed to define the partition weight W_{π_k} :

$$W_{\pi_k} = \sum_{R_j \in \pi_k} w_{R_j}, \quad (1)$$




Figure 1. An example of initial data model in power distribution system [17].




Figure 2. Coarsened graph for Load Flow calculation.

as the sum of all contained regions' weights, and function ϕ_k as:

$$\phi_k = \sum_{R_i, R_j \in \pi_k} Pot_{R_i, R_j} \quad (2)$$

where regions R_i and R_j are in π_k . This function is an indicator of "good connectivity" between regions in the partition.

At the beginning it is necessary to group regions into a defined number of partitions (p), so that weights of these partitions are approximately the same, but never greater than the maximal partition weight M defined as:

$$M = (1 + \varepsilon) \cdot \frac{1}{p} \sum_{k=1}^p W_{\pi_k}, \quad (3)$$

where W_{π_k} is partition weight, p is the number of partitions, and $\varepsilon \in [0, (p-1)/p]$ is the tolerance.

The optimization criterion should obtain the maximum connection inside a partition:

$$F = \max(\sum_{k=1}^p \phi_k), \quad (4)$$

where function ϕ_k is given by Eq. 2, and all partition weights are constrained by:

$$W_{\pi_k} \leq M, \forall k \in \{1, 2, \dots, p\}. \quad (5)$$

Based on these defined optimization criteria, graph partition algorithms are applied. The result of the algorithm is a division of data (grouped into the roots) by partitions (processors). Assuming that the task is to divide the distributed network (shown in Figure 1) into three partitions with tolerance $\varepsilon = 0.1$ ($M = 32.27$), the result would be partitioning (as in Figure 3):

$$\pi_1 = \{R_1, R_2, R_3\}, \pi_2 = \{R_4, R_5, R_6\}, \pi_3 = \{R_7, R_8, R_9\}$$

3. PSO algorithm

PSO algorithm is a stochastic optimization technique based on the collective intelligence of

the population. *Kennedy* and *Eberhart* [18], inspired by the behaviour of a flock of birds looking for food [19], developed *PSO* algorithm which follows common behaviour features of animals that move in groups. A population, the so called swarm, consists of particles which move through multidimensional space and change their positions, depending on their own experience and the experience of the other particles. At first, the algorithm was developed for continual systems, and later - algorithms for discrete systems were introduced: binary *PSO* [20] and integer *PSO* [21-23]. With the binary algorithm each particle from the population can take binary values (0 or 1). In more general cases, such as integer *PSO*, an optimal value is achieved by rounding the real optimum to the nearest integer.




Figure 3. Test data model partitioning in 3 partitions.

Particle representation. Supposing the given graph $G=(V,E)$ with a set of vertices (roots) $V=\{v_1, v_2, \dots, v_d\}$ should be divided into p partitions. In that case, the solution is represented by the vector of d elements, the values of which are indices of the given partitions (integer between 1 and p) [23, 24].

For example, for a graph with 8 vertices, which is divided into 3 partitions, the solution 12332131 refers to the following:

$$\pi_1=\{v_1, v_6, v_8\}; \pi_2=\{v_2, v_5\}; \pi_3=\{v_3, v_4, v_7\};$$

By adapting PSO algorithm to the graph partitioning problem, the dimension of particles is equal to the number of vertices in the graph. Particle positions are updated in a defined number of iteration, in accordance to optimisation criteria, and the bestparticle position is searched.

The change of particle i position is achieved by moving the particle from the previous position, according to equation:

$$x_i^{(k+1)} = x_i^{(k)} + v_i^{(k+1)} \quad (6)$$

where:

- $x_i^{(k)}$ – position of particle i in iteration k ,
- $v_i^{(k+1)}$ – velocity of particle i in iteration $(k+1)$.

Updating of velocity $v_i^{(k+1)}$, for each dimension, is carried out according to:

$$v_i^{(k+1)} = W \cdot v_i^{(k)} + C_1 \cdot r_1 \cdot (b_i - x_i^{(k)}) + C_2 \cdot r_2 \cdot (b_g - x_i^{(k)}) \quad (7)$$

where:

- W – inertia factor,
- C_1 – individuality factor (constant),
- C_2 – social factor (constant),
- $(b_i - x_i^{(k)})$ – individual component (b_i is the best position for particle i),
- $(b_g - x_i^{(k)})$ – social component (b_g is the best position for all particles),
- r_1 and r_2 – random numbers from $[0,1]$.

For the updated position $x_i^{(k+1)}$, the optimisation criteria F is calculated. Position $x_i^{(k+1)}$ is

memorised as the best for particle i - b_i and the population - b_g (if it is better than the previously best position). High velocity of particle movement results in significant position change, so a maximum velocity limit is introduced (v_M):

$$v_i^{(k+1)} = \begin{cases} -v_M, & v_i^{(k+1)} < -v_M \\ v_i^{(k+1)}, & -v_M \leq v_i^{(k+1)} \leq v_M \\ v_M, & v_i^{(k+1)} > v_M \end{cases} \quad (8)$$

In order to get a versatile velocity for all particle dimension, a further modification of already defined velocity $v_i^{(k+1)}$ is:

$$v_i^{(k+1)} = v_i^{(k+1)} \cdot \Delta x_{\max} \cdot r \quad (9)$$

where $\Delta x_{\max} \cdot r$ is the range for velocity modification ($\Delta x_{\max}$ is the highest possible change of position, and r is random number $r \in (0,1]$).

PSO is basically algorithm for solving continual problems. Therefore, it is necessary to adopt *PSO* to the discrete problem and define the allowed space for particle positioning. First, velocity is rounded to the nearest integer:

$$v_i^{(k+1)} = \text{round}(v_i^{(k+1)}) \quad (10)$$

Particle position must have integer values from interval $(0, p]$, so at the and a position modification, according to module p , is carried out:

$$x_i^{(k+1)} = \left| \text{mod}(x_i^{(k+1)}, p) \right| \quad (11)$$

where $\text{mod}(a,b)$ – the remainder while dividing a with b (remainder 0 is related to partition p).

After defined number of iterations, the division of vertices into partitions is achieved as the best particle position in population b_g .

4. Distributed PSO algorithm

Distributed *PSO* algorithm is based on parallel space searching for available solutions [25]. The population (swarm) consists of several distributed sub-swarms, allocated to different processors (shown in figure 4).

Independently of the remaining sub-swarms, the algorithm (a defined number of iterations) is executed on local sub-swarms by each processor. After a formerly defined number of iterations, solutions of different sub-swarms are exchanged. Modification in the distributed algorithm is the introduction of a new parameter – synchronisation period (T_{sync}), which defines the frequency of communication between sub-swarms. Parameter T_{sync} represents the number of iterations after which the global optimum (b_g) will be updated. When sub-swarms receive information about global optimum they change velocity as shown in Eqs. 7-10.

The way of algorithm execution is changed by synchronisation period modification. In case of low T_{sync} values, sub-swarms are more independent and the parallelisation effect is less stressed. In

addition to that, the algorithm is slower due to the communication between sub-swarms. On the other hand, sub-swarms are more independent for higher values of synchronisation period, but this can affect the quality of solution.

5. Experimental results

We tested the models of the real electric power distribution network. The network characteristics are shown in Table 1.

Models *bg54* and *bg63* are different versions of Belgrade (Serbia) power distribution network. *Pec106* is a part of North Carolina (United States) power distribution network model; *it206* is a network model of Milano (Italy); and *bg5x* is Belgrade network model multiplied five times.




Figure 4. Distributed PSO algorithm (system architecture).

Graph name	Total number of elements	Size of initial graph (uncoarsened)		Size of coarsened graph	
		Number of vertices	Number of edges	Number of regions	Number of edges
<i>bg54</i>	1126254	295225	299131	54	44
<i>it206</i>	1787939	431102	434486	206	286
<i>pec106</i>	2284322	762411	766755	106	52
<i>bg63</i>	1196078	300503	304637	63	52
<i>bg5x</i>	5980390	1502505	1523180	315	260

Table 1. Test data models.

5.1 PSO algorithm

PSO algorithm is tested for following parameters:

- number of particles – depends on size of graph:
 - *bg54* and *bg63* - 100 particles,
 - *pec106* – 110 particles,
 - *it106* – 220 particles, and
 - *bg5x* – 330 particles.
- inertia W is set on 0.9 and linearly decreases up to 0.4 for previously given number of iterations (recommendation from[24]),
- velocity v is limited by total number of partition $v \leq |V_{\max}| \leq p$.
- $C_1 = C_2 = 2$.
- tolerance $\varepsilon \in \{0.1, 0.2, 0.3\}$
- maximal number of iterations – $maxIt = 5000$
- number of repetitions for each test – 100 times.

Results representing average values for 100 tests are shown in the table 2.

5.2 Distributed PSO algorithm

Distributed *PSO* (*DPSO*) algorithm is implemented in C# programming language, and swarm clusterisation is done on *Windows HPC Server*

2008 operative system. For communication between sub-swarms *MPI* (*Message Passing Interface*) [26, 27] communication protocol is used.

A comparison of classic (sequential) *PSO* and *DPSO* algorithm on model *bg63* is carried out with following parameters: $W = [0.9, 0.4]$, $C_1 = 2$, $C_2 = 2$, particle dimension is 63, $maxIt = 1000$, $\varepsilon = 0.1$, $p = 6$. The testing of distributed algorithm is done on 6 sub-swarms, on 6 processors. Execution time T_a and the value of the optimisation function F are analysed for the same number of particles in both algorithms (but the swarms in the *DPSO* are divided into 6 sub-swarms).


Test results for sequential and distributed algorithm are shown in the table 3. The results represent average values for 100 repetitions of tests. Tests were carried out for different population sizes (120-480 particles) and for varying synchronization time in *DPSO* algorithm: $T_{sync} \in \{10, 20, 50, 100, 200, 500\}$.

p	<i>Model</i>	0.1	0.2	0.3
2	<i>bg54</i>	392	395	397
	<i>bg63</i>	475	473	484
	<i>pec106</i>	149	155	158
	<i>it206</i>	853	841	849
	<i>bg5x</i>	2379	2334	2342
3	<i>bg54</i>	385	381	383
	<i>bg63</i>	455	462	460
	<i>pec106</i>	146	149	152
	<i>it206</i>	746	760	712
	<i>bg5x</i>	2190	2191	2119
4	<i>bg54</i>	363	370	366
	<i>bg63</i>	444	449	446
	<i>pec106</i>	138	140	142
	<i>it206</i>	674	737	642
	<i>bg5x</i>	2062	2104	2069
5	<i>bg54</i>	336	359	358
	<i>bg63</i>	419	442	428
	<i>pec106</i>	129	135	136
	<i>it206</i>	603	652	633
	<i>bg5x</i>	1949	2077	1980
6	<i>bg54</i>	310	353	358
	<i>bg63</i>	360	421	428
	<i>pec106</i>	120	128	135
	<i>it206</i>	530	588	633
	<i>bg5x</i>	1933	1942	1980
8	<i>bg54</i>	255	270	298
	<i>bg63</i>	237	337	371
	<i>pec106</i>	119	128	130
	<i>it206</i>	421	504	435
	<i>bg5x</i>	1908	1912	1960

Table 2. PSO algorithm results.

No of particles		Parameters	PSO	DPSO					
				Synchronization period (T_{sync})					
PSO	DPSO			10	20	50	100	200	500
120	6x20	F	358	357	355	353	358	358	355
		T_a [s]	5.2	6.3	5.8	5.3	5	4.9	5.5
180	6x30	F	361	361	358	362	360	357	356
		T_a [s]	7.7	6.1	5.8	5.6	5.4	5.4	5.2
300	6x50	F	366	365	366	363.5	365	366	363
		T_a [s]	13.3	6.8	6.7	6.4	6.3	6.2	6.2
360	6x60	F	368	368	364	367	366	365	367
		T_a [s]	15.1	7.3	7	6.7	6.6	6.4	6.4
420	6x70	F	370	371	367	365	369.5	366	366
		T_a [s]	17.5	7.7	7.5	7.2	7.2	7.1	6.9
480	6x80	F	371	370.5	369	371	366	372	371
		T_a [s]	20.9	8.3	8	7.6	7.9	7.5	8.1

Table 3. Sequential (PSO) and distributed PSO (DPSO) algorithms results for 1000 iterations.

Figure 5. Execution time of sequential and distributed PSO (for different T_{sync}).

Execution times of sequential *PSO* and *DPSO* algorithms (for varying synchronization time) are shown in Figure 5.

Based on these results the following can be concluded:

1. Execution time of *DPSO* reduces with increasing synchronization time (T_{sync}),
2. If the population size is 300 or more particles - execution time of *DPSO* is significantly less (2 times or more) than execution time of *PSO*,
3. When the population is small - frequent communication (lower value of T_{sync}) between sub-swarms is required in order to achieve the same results as a sequential algorithm,
4. If the number of particles in sub-swarms is not less than the size of the particle, *DPSO* gives better results for the criterion function F and significantly shorter execution time,
5. The execution time of *DPSO* with a population 6x80 particles is comparable to the execution time of the sequential *PSO* algorithm (with population of 180 particles), and much better results are achieved (372/361) by *DPSO*,
6. Using *DPSO* algorithm is recommended in case of larger graphs. If the size of the particle is greater than 300 (i.e., if the graphs have more than 300 vertices), then the use of parallel *DPSO* algorithm is reasonable.

6. Conclusion

The paper presents a method for partitioning a data model of the power distribution network in order to optimize the analytical power calculations. The classical *PSO* (sequential) and distributed *PSO* algorithm are applied, and experiments are performed in the distributed multiprocessor system. Experiments showed that the distributed *PSO* algorithm achieved better results than the sequential *PSO* algorithm.

References

- [1] V. Strezoski et al., "DMS - Basis for Increasing of Green Distributed Generation Penetration in Distribution Networks", *Thermal Science*, vol.16, Supplement, pp. 189-203, 2012.
- [2] S. Vukmirovic et al., "Optimal Workflow Scheduling in Critical Infrastructure Systems with Neural Networks", *Journal of Applied Research and Technology*, vol. 10 no.2, pp. 114-121, April 2012.
- [3] F. Jiyuan and S. Borlase, "The Evolution of Distribution", *IEEE Power & Energy Magazine*, pp. 63-68, march/april 2010.
- [4] G. Heydt, "The next generation of power distribution systems", *IEEE Transactions on Smart Grid*, vol. 1, no. 3, pp. 225-235, 2010.
- [5] V. Strezoski et al., "Osnovne energetske funkcije za analizu, upravljanje i planiranje pogona srednjenaponskih distributivnih mreža", IV skup Trendovi Razvoja: „Nove tehnologije u elektrodistribuciji“, Kopaonik, 1998.
- [6] D. Capko et al., "An Optimal Relationship-Based Partitioning of Large Datasets", 14th East-European Conference on Advances in Databases and Information Systems, Novi Sad, *Lecture Notes in Computer Sciences*, vol. 6295, pp.547-550., 2011.
- [7] M.R. Garey and D.S. Johnson, "Computers and Intractability: A Guide to the Theory of NP-Completeness", W.H. Freeman, San Francisco, 1979.
- [8] H.C. Kuo and C. H. Lin, "Cultural evolution algorithm for global optimizations and its applications", *Journal of Applied Research and Technology*, vol. 11, no. 4, pp.510-522., 2013.
- [9] T.N. Bui and B.R. Moon, "Genetic Algorithm and Graph Partitioning", *IEEE Trans. Computers*, vol. 45, no. 7, pp. 841-855., 1996.
- [10] G. Karypis and V. Kumar, "A fast and high quality multilevel scheme for partitioning irregular graphs", *SIAM Journal of Scientific Computing*, vol.20, no.1, pp. 359-392., 1998.
- [11] IEC 61970 Energy management system application program interface (EMS-API) – Part 301: Common Information Model (CIM) Base, IEC, Edition 2.0, 2007.

- [12] IEC/TR 61968-11 Application integration at electric utilities - System interfaces for distribution management - Part 11: Common information model (CIM) extensions for distribution, IEC, Edition 1.0, 2010.
- [13] IEC 61970 Energy management system application program interface (EMS-API) – Part 403: Generic data access, IEC, 2008.
- [14] OMG Specification: Utility Management Systems (UMS) Data Access Facility DAF, Version 2.0.1, 2005.
- [15] A. Erdeljan and D. Capko, "Analiza primene DAF i GDA specifikacija za pristup objektnom modelu UMS-a", 51. Konferencija ETRAN 2007., Herceg Novi, jun 2007.
- [16] S. Vukmirovic et al., "Extension of the Common Information Model with Virtual Meter", *Electronics and Electrical Engineering*, Kaunas: Technologija, vol.107, no.1., pp. 59-64, 2011.
- [17] D. Capko et al., "A Hybrid Genetic Algorithm for Partitioning of Data Model in Distribution Management Systems", *Information technology and control*, vol. 40, no. 4, pp. 316-322, 2011.
- [18] J. Kennedy and R. Eberhart, "Particle swarm optimization", In: Proceedings of the 1995 IEEE International Conference on Neural Networks (ICNN), IEEE Service Center, Piscataway, New Jersey, vol.4, pp.1942–1948, 1995.
- [19] E.O. Wilson, „Sociobiology: The new synthesis“, Belknap Press, Cambridge, 1975.
- [20] J. Kennedy and R. Eberhart, "A discrete binary version of the particle swarm algorithm", In: Proceedings of the 1997 IEEE International Conference on Systems, Man, and Cybernetics, IEEE Service Center, Piscataway, New Jersey, vol. 5, pp. 4104–4108, 1997.
- [21] E. Laskari et al., "Particle swarm optimization for integer programming", In: Proceedings of the IEEE Congress on Evolutionary Computation, Honolulu, Hawaii USA, vol. 2, pp. 1582–1587, 2002.
- [22] D. Capko et al., "PSO algorithm for Graph Partitioning", 17th Telecommunication Forum 2009, Belgrade, 2009.
- [23] H. Rezazadeh et al., "Linear programming embedded particle swarm optimization for solving an extended model of dynamic virtual cellular manufacturing systems", *Journal of Applied Research and Technology*, vol.7, no. 1, pp. 83-108, April 2009.
- [24] R. Eberhart and Y. Shi, "Particle Swarm Optimization: Developments, Applications and Resources", In: Proceedings of the IEEE Congress on Evolutionary Computation (CEC 2001), Seoul, Korea, 2001.
- [25] G. A. Laguna-Sánchez et al., "Comparative Study of Parallel Variants for a Particle Swarm Optimization Algorithm Implemented on a Multithreading GPU", *Journal of Applied Research and Technology*, vol.7, no. 3, pp. 292-307., December 2009.
- [26] W. Gropp, "Using MPI, 2nd Edition: Portable Parallel Programming with the Message Passing Interface", Cambridge, MIT Press, 1999.
- [27] MPI Forum: MPI: A Message-Passing Interface Standard, Version 2.2, High Performance Computing Center Stuttgart, 2009.